

NOTE : POSTS MAY STOP 500 mm MAX. BELOW TOP OF GLASS.

RUBBER GASKETS AS REQUIRED.

APE POSTS @ 1000 MAX. CRS.

10 mm TOUGHENED SAFETY GLASS WITH MINIMUM SURFACE COMPRESSION OF 69 mPa.

NOTE : ADDITIONAL REQUIREMENTS FOR SAFETY GLASS ARE REQUIRED WHERE BALUSTRADE IS MORE THAN 5 metres ABOVE FLOOR / GROUND. REFER AS. 1288 / AMDT 2 / 2011-11-11, CLAUSE 3.8

'BERP' SQUARE BASE PL. (115 x 100 x 12 TH. WITH 4No. 12 DIA. HOLES)

GMC COMBO MOUNT

M10 'CHEMSET' STAINLESS STEEL ANCHORS
90 mm MIN. EMBEDMENT.
50 mm MIN. EDGE DISTANCE.

'CHEMSET' TO BE RAMSET 800 SERIES OR EQUIVALENT N32 MIN. CONC. GRADE

APE 'BERP' BASEPLATE (SCALE 1:2)

APE (SCALE 1:2)

DESIGN HORIZONTAL LIVE LOAD = 0.75 kN/m

APPLICABLE FOR WIND REGIONS A & B TO AS.1170 , TERRAIN CATEGORY 3

REGION A MAXIMUM BUILDING HEIGHT 10 m

REGION B MAXIMUM BUILDING HEIGHT 8 m

B	REFERENCE FOR GLAZING ABOVE 5m AMENDED	24.11.2014
A	ISSUED FOR CONSTRUCTION	9.01.2014
REV	COMMENTS	DATE

AXIOM GROUP
P.O. BOX 94 , WERRIBEE. VIC. 3030
PH. 1300 652 336 EMAIL. sales@axiomgroup.com.au
FAX. 1300 611 789 WEB. axiomgroup.com.au

CLIVE STEELE PARTNERS PTY LTD
CONSULTING ENGINEERS - STRUCTURAL & CIVIL



BUILDING 6
62/195 WELLINGTON ROAD
CLAYTON, VICTORIA
AUSTRALIA. 3168
Telephone (03) 9545 0223
Facsimile (03) 9545 3022
Email csp@clivesteele.com.au
A.C.N. 005 363 735 A.B.N. 92 627 427 761

VECTRO PRIVACY SCREENS.
APE SEMI - FRAMELESS BALUSTRADE

CONCRETE SLAB MOUNT

DRG. No.

16996 - C - S04

REV. B

DESIGNED	IKF	DATE	JAN '14
DRAWN	AB	SCALE	1:2
REF No		ROLL No.	